

CITY OF TEMPLE, TEXAS
DRAUGHON-MILLER CENTRAL TEXAS REGIONAL AIRPORT

TxDOT CSJ No. 2509TEMPL

ADDENDUM NO. 3

August 7th, 2025

TO ALL PROSPECTIVE BIDDERS:

All bidders shall acknowledge receipt of this and all other addenda on page 7 of 8 of the Bid Form. **Failure to acknowledge receipt of an addendum may be cause for rejection of the bid.** This addendum becomes a part of the contract documents. All provisions of the original plans, specifications, and contract documents shall remain in full force and effect, except as modified by this addendum.

A. You are hereby notified of the following amendments to the Bid Form for the subject project.

- a) **Changed Quantities**
a. **Lime per Tons**

B. You are hereby notified of the following amendments to the Contract Documents/Specifications for the subject project.

The Bid Opening Date has been rescheduled to Thursday, August 14, 2025, 1 PM.

C. You are hereby notified of the following amendments to the Construction Plans for the subject project.

None.

D. Additional Clarification and Questions:

See attached.

ADDENDUM NO. 3 ISSUED BY:

H.W. Lochner, Inc.


Chris A. Whitfield, P.E.
Project Manager

CAW/SLS
Enclosures
pc: 19910

TBPE Firm Registration No. 10488

Clarifications:

1. Additional clarification on fill material from Questions in Addendum 1 and 2.

Contractor can assume that material from onsite for embankment and that it will meet spec. Please Review the Earthwork Table on plan sheet 2.0.

2. Additional clarification on fill material from questions in addendum 1 and 2.

All Borrow Excavation, Contractor Furnished material will need to be tested. These areas have not been surveyed, therefore, the quantity is unknown. Fill material shall be fine-grained soils with 50% or more passing the No. 200 sieve and be classified as lean clay (CL) or fat clay (CH).