

To: All Plan Holders**Project:** Electrical Improvements Project**Airport:** Mid Valley Airport**KSA Project No.:** WSL.015**Date:** Thursday, March 31, 2021**Client Project No.:** TxDOT CSJ No. 2021WESLA

The plans, specifications, and contract documents are modified as described below. All bidders shall acknowledge receipt of this and all other addenda on page 7 of 7 on the revised bid form titled **REVISED PER ADDENDUM NO. 3**. This addendum becomes a part of the contract documents. All provisions of the original plans, specifications, and contract documents shall remain in full force and effect, except as modified by this addendum.

I. Bid Form

Replace with the attached **Revised Bid Form**. Note that the award of bids will be based on the bid items and quantities listed in the **Revised Bid Form**. Any variance in the bid submittals from the **Revised Bid Form** will result in the bid being disqualified.

II. Attachments

- A. Revised Bid Form
- B. Contractor Questions and Responses

Addendum No. 3 Issued By:
KSA



Nathan T. Mikell, P.E.
Senior Project Engineer



TBPE Firm Registration No. F-1356

To: All Plan Holders

Project: Electrical Improvements Project

Airport: Mid Valley Airport

KSA Project No.: WSL.015

Date: Monday, March 31, 2021

Client Project No.: TxDOT CSJ No. 2021WESLA

1. Question: The bid form for this project states that the proposed PAPI is an L-881. However, the L-125 specification and the plans sheets reflect an L-880 PAPI. Please clarify.

Response: The proposed PAPI for this project shall be an L-880. Please refer to the revised bid form that is included with this addendum where the item description for pay item 2.09 has been changed to reflect this. The summary of quantities sheet will be updated to reflect this change on the issued for construction set of plans.